

Table 5.3. Average Flue Gas Desulfurization Costs, 1994 through 2005

Year	Average Overhead & Maintenance Costs (mills per kilowatthour) ¹	Average Installed Capital Costs (dollars per kilowatt)
1994.....	1.14	127.00
1995.....	1.16	126.00
1996.....	1.07	128.00
1997.....	1.09	129.00
1998.....	1.12	126.00
1999.....	1.13	125.00
2000.....	.96	124.00
2001.....	1.27	130.80
2002.....	1.11	124.18
2003.....	1.23	123.75
2004.....	1.38	144.64
2005.....	1.23	141.34

¹ A mill is one tenth of one cent.

Notes: • These data are for plants with a fossil-fueled steam-electric capacity of 100 megawatts or more. • Beginning in 2001, data for plants with combustible renewable steam-electric capacity of 10 megawatts or more were also included. • Data for Independent Power Producer and Combined Heat and Power plants are included beginning with 2001 data. • Totals may not equal sum of components because of independent rounding.

Source: Energy Information Administration, Form EIA-767, "Steam-Electric Plant Operation and Design Report."